

TO: Mary Anderson

FROM: Ed Kerzinski

DATE: September 28, 2009

RE: October ISTS BOA Summary

Nghi Nguyen

ISTS permit # 21965 was issued 8/6/09. Permit was issued for a 3 bedroom dwelling. System to consist of a 1000 gallon septic tank, 1000 gallon pump tank dosing a 6' x 75' pressure mound. Expansion area available next to primary system site.

Ann Treacy **7008 Bear Island Road** **Fredenberg Twp**

Permit # 22090 was issued 9/14/09. Permit was issued for a 1 bedroom seasonal dwelling. System to consist of a pit privy (replacement) for a bunkhouse with no well on site, no plumbing in bunkhouse.

Vince Repesh **5139 2nd Ave** **Fredenberg**

Design submitted to Environmental Services Department for review, (no permit issued). Design is for a 3 bedroom dwelling. System would consist of a 1000 gallon septic tank, 500 gallon pump tank dosing a 10' x 45' pressure bed system. Available expansion area is available near the primary ISTS site.

Hal Heyer **7120 NW Island Lake Rd** **Unorg 53-15 Twp**

ISTS permit # 21486 was issued 12/09/2008. An operating permit was issued for a replacement system for a 3 bedroom dwelling. The system is to consist of a 2000 gallon 2 chamber septic tank and a 1000 gallon pump chamber dosing a 20' x 24' single pass bottom drain sand filter.

Tom Stender **4864 NW Island Lake Rd** **Unorg 53-15 Twp**

(From June 2009 BOA Meeting). Permit # 14 (2-1) was issued 8/8/78. System was sized for a 2 bedroom dwelling. System consists of a 1000 gallon septic tank, with 120 lineal feet of trench drain field. A compliance inspection was performed on the system July 19, 2007. The system was found to be non-conforming due to the 15" vertical separation from seasonal saturated soils to drain field bottom. Expansion area is available near existing system.